

SOLICITATION 12444026Q0119
DUCT CLEANING SERVICES ON THE OZARK-ST FRANCIS NATIONAL FOREST, ARKANSAS
QUESTIONS & ANSWERS

Questions are in black text & Answers are in blue text

QUESTION SET 1 RECEIVED JUNE 17 2026

QUESTION SET 1 ANSWERED JUNE 17 2026

1. Q: could you please confirm the due date and time for this requirement?

A: confirmed, solicitation v2 responses are due to richard.kandrach@usda.gov by 06-28-2026 by 0900AM ET per sam.gov

2. Q: Could you please confirm how many supply registers and return registers there are?

A: There are 98 supply registers.

3. Q: I understand that negative pressure is not recommended. We usually carry out duct cleaning using positive pressure. Would that be acceptable for this project?

A: No, Negative pressure is the industry standard and is the process we have specified.

4. Q: How many vents? What is the square footage? And how many units?

A: 98 Supply and 18 return registers. Estimated Sq Ft is 15,000. 12 geothermal units.

5. Q: Will a site visit be allowed?

A: Site Visit 06-25-2026 @ 10:00AM to schedule contact Danny Sims danny.sims@usda.gov

QUESTION SET 2 RECEIVED -- TBD